

Water Quality Report

Name of Division: P.H.-Division,		Lakhisarai		District:- Lakhisarai		Reporting Date:-		18.11.2024	
Sample collected By:-		SCHOOL STAFF				Sample received On:-		12.11.2024	
Reference No.-N/A						Sampling Date:-		12.11.2024	

PHYSICO-CHEMICAL & BACTERIOLOGICAL TEST REPORT																				
Sl.No	Block Name	Panchayat Name	Village Name	Habitat Name	Location Detail	Type of Source	TEST RESULT													
							pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	SO4	Alka	NO3	As	Fe	T Coil
Desirable Limit*(IS 10500:2012)							6.5-8.5	1.00	umho lcm	Mg/l	Mg/l	Mg/l	Mg/l	Mg/l	Mg/l	Mg/l	Mg/l	Mg/l	Mg/l	MPN 100 ml
Permissible Limit in absence of alternate source							NR	5.00	.	500	200	75.00	30.00	250.00	200.00	200.00	45.00	0.010	0.10	.
1	Lakhisarai		Mount Litera Zee School		Boring		7.10	2.1	387	252	84	33.6	11.6	34	400.00	600.00	NR	NR	0.30	.
2	Lakhisarai		Mount Litera Zee School		Boring		7.19	2.2	380	247	85	32.1	11.9	32	2	71.2	2.6	BDL	0.1	-ve

Research Assistant (Chemist)
P.H.-Division, LAKHISARAI

Assistant Engineer
P.H.-Division, LAKHISARAI